

**SECTION 1016**  
**SELECT MATERIALS**

**CLASS IV**

Select material is a coarse aggregate material meeting the gradation requirements of standard size ABC as described in Section 1010.

**CLASS V**

Select material is a coarse aggregate material meeting the gradation requirements of standard size 78M in Table 1005-1 as described in Sections 1005 and 1006.

**CLASS VI**

Select material is a coarse aggregate material meeting the gradation requirements of standard size 57 in Table 1005-1 as described in Sections 1005 and 1006.

**CLASS VII**

Select material is clean, unweathered durable, blasted rock material. While no specific gradation is required, the below criteria will be used to evaluate the materials for visual acceptance by the Engineer.

- (A) At least 50% of the rock has a diameter of from 1.5 feet to 3 feet,
- (B) 30% of the rock ranges in size from 2 inches to 1.5 feet in diameter, and
- (C) Not more than 20% of the rock is less than 2 inches in diameter. No rippable rock will be permitted.